

Preliminary Prioritization of Substation Relocations	History of Flooding	100-Year Flood Plan	500-Year Flood Plan	# of Customers (Distribution)			Estimate Cost (In Millions \$)	Notes
				Residential	Commercial	Industrial		
Brownsville Distribution Substation	Yes	Yes	-	1057	142	0	3.1	
Rochester Distribution Substation	Yes	Yes	-	916	152	0	4	
Fair Haven Distribution Substation	Yes	Yes	Yes	818	155	0	3.2	
Taftsville Transmission	Yes	Yes	Yes	731	126	0	4.7	
Dover Distribution	No	Yes	-	3000	488	2	6.6	
Windsor Transmission and Distribution Substation	No	Yes	Yes	2294	467	0	7	
Riverside Distribution Substation	No	Yes	Yes	1594	288	0	3	
Winooski Transmission Substation	No	Yes	Yes	n/a	n/a	0	1	
Woodstock Distribution Substation	No	No	Yes	2697	612	0	6	
East Jamaica Distribution Substation	No	No	Yes	1987	190	0	3.5	
Waterbury Distribution Substation	No	No	No	1253	310	1	NA	Completed 2015
Barre South End Distribution Substation	No	No	No	2047	457	0	NA	Completed 2018

Substations that have already been moved out of the floodway.